

# **Emergency Luminaire with LED**

Series EXLUX 6009/4



# Contents

1	General Information	3
1.1	Manufacturer	3
1.2	Information regarding the operating instructions	3
1.3	Further documents	3
1.4	Conformity with standards and regulations	3
2	Explanation of the symbols	
2.1	Symbols in these operating instructions	4
2.2	Warning notes	4
2.3	Symbols on the device	5
3	Safety notes	5
3.1	Operating instructions storage	5
3.2	Safe use	5
3.3	Intended Use	6
3.4	Modifications and alterations	6
4	Function and device design	6
4.1	Function	
4.2	Device design	7
5	Technical data	9
6	Engineering	
6.1	Mains operation	
6.2	Emergency light blocking	16
7	Transport and storage	
7.1	General	
7.2	Batteries	
8	Mounting and installation	
8.1	Dimensions / fastening dimensions	
8.2	Removing protective foil	
8.3	Mounting / dismounting, operating position	
8.4	Installation	
9	Commissioning	
10	Operation	
	Operating Modes	
	Functional and rated operating time test	
	Indications	
10.4	Troubleshooting	
11	Maintenance, Overhaul, Repair	
11.1	Maintenance	
11.2	Repair	
11.3	Returning the device	
12	Cleaning	
13	Disposal	
14	Accessories and Spare parts	39



## 1 General Information

# 1.1 Manufacturer

R. STAHL Schaltgeräte GmbH

Am Bahnhof 30 74638 Waldenburg

Germany

Phone: +49 7942 943-0 Fax: +49 7942 943-4333

Internet: r-stahl.com E-mail: info@r-stahl.com

R. STAHL Schaltgeräte GmbH Business Unit Lighting & Signalling

Nordstr. 10 99427 Weimar Germany

Phone: +49 3643 4324 Fax: +49 3643 4221-76

Internet: r-stahl.com E-mail: info@r-stahl.com R. STAHL (P) LTD., Plot No. - 5

Malrosapuram Road, Sengundram Indl. Area Singaperumal Koil, Kancheepuram Dist.,

Tamil Nadu - 603 204, INDIA

Phone: +91 44-67 300 600 Fax: +91 44-67 300 700 Internet: r-stahl.com/en/in E-mail: sales@rstahl.net

# 1.2 Information regarding the operating instructions

ID-No.: 265135 / 600960300190 Publication Code: 2020-11-23·BA00·III·en·03

The original instructions are the English edition.

They are legally binding in all legal affairs.

## 1.3 Further documents

Data sheet

For documents in additional languages, see r-stahl.com.

# 1.4 Conformity with standards and regulations

See certificates and EU Declaration of Conformity: r-stahl.com.

The device has IECEx approval. For certificate please refer to the IECEx homepage: http://iecex.iec.ch/

Further national certificates can be downloaded via the following link:

https://r-stahl.com/en/global/support/downloads/.



# 2 Explanation of the symbols

# 2.1 Symbols in these operating instructions

Symbol	Meaning
i	Tips and recommendations on the use of the device
EX	Danger due to explosive atmosphere
	Danger due to live components

# 2.2 Warning notes

Warnings must be observed under all circumstances, in order to minimize the risk due to construction and operation. The warning notes have the following structure:

- Signalling word: DANGER, WARNING, CAUTION, NOTICE
- Type and source of danger/damage
- · Consequences of danger
- Taking countermeasures to avoid the danger or damage



# **DANGER**

Danger to persons

Non-compliance with the instruction results in severe or fatal injuries to persons.



## **WARNING**

Danger to persons

Non-compliance with the instruction can result in severe or fatal injuries to persons.



# **CAUTION**

Danger to persons

Non-compliance with the instruction can result in light injuries to persons.

# **NOTICE**

Avoiding material damage

Non-compliance with the instruction can result in material damage to the device and / or its environment.



# 2.3 Symbols on the device

Symbol	Meaning
C € 0158	CE marking according to the currently applicable directive.
<b>(Ex)</b>	According to marking, device approved for hazardous areas.

# 3 Safety notes

# 3.1 Operating instructions storage

- Read the operating instructions carefully.
- · Store the operating instructions at the mounting location of the device.
- Observe applicable documents and operating instructions of the devices to be connected.

#### 3.2 Safe use

## Before mounting

- · Read and observe the safety notes in these operating instructions!
- Ensure that the contents of these operating instructions are fully understood by the personnel in charge.
- Use the device in accordance with its intended and approved purpose only.
- Always consult R. STAHL Schaltgeräte GmbH if using the device under operating conditions which are not covered by the technical data.
- We cannot be held liable for damage to the device caused by incorrect or unauthorised use or non-compliance with these operating instructions.

## For assembly and installation

- Observe national assembly and installation regulations (e.g. IEC/EN 60079-14).
- Observe national safety and accident prevention regulations.
- During installation and operation, observe the information (characteristic values and rated operating conditions) on the type plates and data plates and information signs located on the device.
- Before installation, make sure that the device is not damaged.

## Maintenance, repair, commissioning

- Before commissioning, make sure that the device is not damaged.
- Work on the device, such as installation, maintenance, overhaul, repair, may only be carried out by appropriately authorised and trained personnel.
- Perform only maintenance work or repair described in these operating instructions.

# 3.3 Intended Use

The luminaire 6009/4 is equipment

- · for lighting areas, work spaces and objects
- for emergency lighting in case of power failure.
- · can be used indoors and outdoors
- · for stationary mounting
- for use in Zones 1, 21, 2, 22 and in the safe area

# 3.4 Modifications and alterations



## **DANGER**

Explosion hazard due to modifications and alterations to the device! Non-compliance results in severe or fatal injuries.

· Do not modify or alter the device.



No liability or warranty for damage resulting from modifications and alterations.

# 4 Function and device design



# **DANGER**

Explosion hazard due to improper use!

Non-compliance results in severe or fatal injuries.

- Use the device only in accordance with the operating conditions described in these operating instructions.
- Use the device only for the intended purpose specified in these operating instructions.

## 4.1 Function

## **Application range**

The luminaire 6009/4 is equipment used for lighting areas, work equipment and objects. It can be used indoors or outdoors and is suitable for emergency lighting in case of power failure.

The luminaire is approved for use in hazardous areas of Zones 1, 21, 2 and 22.

#### Mode of operation


A weekly functional test has been permanently integrated. An annual rated operating time test can be deactivated and activated.

When opened using a central lock, the luminaire switches off automatically (optional).

The operating hours can be determined and the luminaire can be dimmed and switched via an optional DALI interface.




# 4.2 Device design



- 1 I.S. Module
- 2 Control gear
- 3 Translucent cover
- 4 Battery

- 5 Cable entry
- 6 Connection terminal
- 7 Luminaire enclosure
- 8 Battery enclosure



- 9 LED indicator
- 10 Mounting plate top side
- 11 LED PCB
- 12 Diffuser

# **Explosion Protection**

## Global (IECEx)

Gas and dust

IECEx IBE 16.0038

Ex db eb ib mb op is IIC T4 Gb Ex tb op is IIIC T100 °C Db

**Europe (ATEX)** 

Gas and dust

**IBExU 16 ATEX 1199** 

#### Certifications and certificates

Certificates

IECEx, ATEX

#### **Technical Data**

#### **Electrical data**

Rated operational

voltage

Rated insulation

Rated operational current

voltage

AC: 100 to 240 V ±10 %; 50 to 60 Hz

250 V

	Size 2		Size 4	
At nominal voltage	110 V	230 V	110 V	230 V
During stand-by switching mode	< 0.08 A	< 0.08 A	< 0.08 A	< 0.08 A
In continuous mode	0.24 A	0.13 A	0.43 A	0.21 A

Inrush current

 $I_{peak}$  = 63 A; Δt = 115 μs

maximum number of luminaires per miniature circuit breaker at 230 V:

Туре	10 A	16 A	20 A	25 A
В	11	17	22	28
С	18	29	37	46
K	37	59	74	93

Power factor

	Size 2		Size 4	
At nominal voltage	110 V	230 V	110 V	230 V
	≥ 0.98	≥ 0.90	≥ 0.99	≥ 0.95

THD

Size 2: < 15 %

Size 4: < 8 %

Protection class

I (with internal PE connection)



#### **Luminous characteristics**

Standard Light colour: Neutral white

> Colour temperature [K]: 5,000 K Colour rendering R<sub>a</sub>: ≥80

Application example: lighting of desktops

	6009/4.2.		6009/4.4.	
Size	2		4	
Power consumption [W]	25		45	
Diffuser	with	without	with	without
Luminous flux [lm]	2,910	3,230	5,810	6,460
Luminaire efficacy [lm/W]	116	129	129	144

Alternative

Light colour: Champagne Colour temperature [K]: 3,000 K

Colour rendering R<sub>a</sub>: ≤80

Application example: External lighting for streets and squares

Light colour: Warm white Colour temperature [K]: 4,000 K Colour rendering R<sub>a</sub>: ≥80

Application example: Lighting of desktops

Light colour: Cool white

Colour temperature [K]: 6,500 K Colour rendering R<sub>a</sub>: ≥80

Application example: Lighting outside areas

For luminous flux and luminaire efficacy, see the table above

Yellow phosphorus converted

Light colour: Yellow

Application example: no impact on animals in lighting

	6009/4.2.		6009/4.4.	
Size	2		4	
Power consumption [W]	21		39	
Diffuser	with	without	with	without
Luminous flux [lm]	2,180	2,420	4,360	4,840
Luminaire efficacy [lm/W]	105	115	112	124



Green

Light colour: Green

Application example: eyewash stations, safety showers and in the offshore area and near ports

	6009/4.2.		6009/4.4.	
Size	2		4	
Power consumption [W]	21		38	
Diffuser	with	without	with	without
Luminous flux [lm]	2,110	2,340	4,240	4,710
Luminaire efficacy [lm/W]	100	111	112	124

Red


Light colour: Red

Application example: offshore area or near ports

	6009/4.4.	
Size	4	
Power consumption [W]	29	
Diffuser	with	without
Luminous flux [lm]	1,540	1,710
Luminaire efficacy [lm/W]	53	59

Luminous flux decline

at ambient temperature



A: Size 2; 230 V B: Size 4; 230 V C: Size 2; 110 V D: Size 4; 110 V

#### **Ambient conditions**

Operating temperature range

#### Size 2, 4: Variant: with or without DALI

Light colour: Neutral white, champagne, warm white, cool white, red and yellow phosphorus converted without through wiring: -30 to +60 °C (1, 2)  $I_N$  through wiring  $\leq$  10 A: -30 to +55 °C <sup>(1, 2)</sup>  $I_N$  through wiring  $\leq$  16 A: -30 to +50 °C <sup>(1)</sup>

Light colour: Green

without through wiring: -30 to +50 °C (1)  $I_N$  through wiring  $\leq$  10 A: -30 to +50 °C <sup>(1)</sup>  $I_N$  through wiring  $\leq$  16 A: -30 to +50 °C <sup>(1)</sup>

# (1) Rated operating time during emergency light operation

is guaranteed within an ambient temperature range of -5 to +50 °C. This also applies to charging and discharging of the battery. The rated operating time might be reduced if used outside this temperature range.

# (2) Battery service life

is guaranteed within an ambient temperature range of -30 to +50 °C according to IEC/EN 60598-2-22.

-30 to +60 °C

Storage

#### Service life

LED

	Neutral white, champagne, warm white, cool white, red	Yellow phosphorus converted	Green
L <sub>90</sub> B <sub>50</sub>	> 100,000 h	> 33,000 h	> 30,000 h

 $L_xB_v$ 

At the end of the service life:

- · Luminous flux decline to "x" percent
- Up to "y" percent of all luminaires fall below "x"

LED control gear

C10 at 45 °C ≥ 100,000 h C10 at 60 °C ≥ 50,000 h



#### Mechanical data

Degree of protection | IP66 / IP67 (IEC 60598)

IP64 if a breather is used

Impact strength (IK code)

IK10 (IEC 62262)

Material

Enclosure polyester resin, glass fibre reinforced
Enclosure colours Grey colour, similar to RAL 7035

Lamp cover Polycarbonate

Seal Silicone seal, foamed into the translucent cover

Luminaire locking Central lock for M8 / A/F 13 box spanner;

the translucent cover can be swivelled on its hinge

#### Mounting / Installation

Cable glands

## Standard luminaire

Plastic: 2 x M25 x 1.5 cable entries 8161 and

2 x M25 x 1.5 stopping plugs 8290 (enclosed)

Metal: 2 x metal plates M20 x 1.5 connected by means of PE for metal

cable entries

Attention: cable entries must be ordered separately

Special max. 4 drilled holes for M20, M25, NPSM ½"

version: max. 2 drilled holes for NPT 3/4"

Metal cable glands: M20 x 1.5, M25 x 1.5;

earthing metal cable entries

using metal plates

Connection Spring clamp terminals

Standard: 6-pole: L1, L2, L3, L', N, PE

with DALI: 8-pole: L1, L2, L3, L', N, PE, D1, D2

Clamping range: 1 x 1.5 to 6 mm<sup>2</sup> (solid)

1 x 1.5 to 4 mm<sup>2</sup> (finely stranded)

1 x 1.5 to 6 mm<sup>2</sup> (finely stranded with core end sleeves)

(2 free clamping units per pole available)

Through wiring

Standard with

**luminaire** Luminaries are equipped with internal through wiring.

Connection of ingoing and outgoing leads on

opposite sites is possible. Terminals: See Tech. data

Wiring cross section of the supply line connection:

2.5 mm<sup>2</sup> for max. 16 A

(Observe service temperature)

Optional without

On the connection side, there are 2 bores M25 x 1.5 for cable entries for through wiring of the connection line

(ingoing and outgoing leads on one side).



Assembly Standard luminaire

> 2 x M8 insert nuts in the enclosure Standard:

Special: Mounting grooves in the enclosure for use of fastening

> and ceiling rails for variable luminaire mounting (variable mounting distances for luminaires

L = 700 mm: 320 to 480 mm; L = 1310 mm: 670 to 930 mm)

Control gear

Emergency light mode

In case of power failure the LEDs are supplied by the battery

Rated operating time

at optimal ambient temperature of the battery:

Battery	Rated operating time	Emergency light output	
capacity		Size 2	Size 4
7 Ah	1.5 h	65 %	35 %
	3.0 h	35 %	20 %

Switchover voltage

From mains to battery operation

at  $U_N = 230 \text{ V} < 179 \text{ V}$ at U<sub>N</sub> = 110 V < 84 V

From battery to mains operation

at  $U_N = 230 \text{ V} > 190 \text{ V}$ at  $U_N = 110 \text{ V} > 94 \text{ V}$ 

Switching time ≤ 0.5 s

**Battery set** 

Version NiCd battery, gas-tight

6 V Operating voltage 7 Ah Capacity

Replacing the battery set

When opening the battery enclosure, the connection between the battery

and the control gear is disconnected by means of a switch.

The battery set can be replaced after disconnecting the plug-in contacts.

Optional

**DALI-connection** DALI interface in accordance with IEC 62386-202:2009-08 and

IEC 62386-207:2009-08

Breather Breather 8162/1 from R.STAHL Schaltgeräte GmbH

The breather guarantees compliance with degree of protection IP64 in all mounting positions. The breather may not be used in atmospheres

with corrosive gasses.

For further technical data, see r-stahl.com.




# 6 Engineering

# 6.1 Mains operation


# 6.1.1 Stand-by operation

· The light fitting is switched off.




# 6.1.2 Continuous operation

• The light fitting is switched on.




# 6.1.3 Normal lighting operation

• The light fitting is operated by normal lighting.




# 6.1.4 Control with DALI

The light fitting is switched using DALI control.



# 6.2 Emergency light blocking

A remote switch for emergency light blocking can be connected to terminals 10 and 12 of the control gear.



Power supply operation

Power failure

# Remote switch is closed

Switching on the luminaire depending on operation mode Emergency light function

# Remote switch is opened

Switching on the luminaire depending on operation mode No emergency light function




# 6.2.1 Connection version remote switch


The remote switch is directly connected to the control gear.

The following connection versions are possible:

# Point-to-point connection



# Linear connection



The following conductor specifications must be observed during connection.

	Point-to-point connection	Linear connection
maximum conductor length		
x 1	500 m	100 m
x 2		50 m
x 3		500 m
maximum number of light fittings	50	30
Cable cross section	1.5 mm <sup>2</sup>	1.5 mm <sup>2</sup>

#### 7 Transport and storage

#### 7.1 General

- Transport and store the device only in the original packaging.
- Store the device in a dry place (no condensation) and vibration-free.
- Do not drop the device.

#### 7.2 **Batteries**

- Do not transport together with other materials.
- Do not transport in explosive dust atmosphere.
- Handle with care.
- Store protected from fire, sources of dust, harmful gases and liquids.
- · Store in a dry and cool location.

# **NOTICE**

Risk of deep battery discharge due to exceeded storage!

Non-compliance can result in material damage!

 The battery should be charged within 26 weeks from date of production by means of operating the luminaire.

#### Recommendation:

Store battery at an ambient temperature of +5 to +25 °C and a relative humidity of 65 ±5 %. The storage period is reduced of up to one month if stored outside this temperature range.

#### Mounting and installation 8



# **DANGER**

Explosion hazard due to incorrect installation of the device! Non-compliance results in severe or fatal injuries.

- Carry out installation strictly according to the instructions and national safety and accident prevention regulations to maintain the explosion protection.
- Select and install the electrical device so that explosion protection is not affected due to external influences, i.e. pressure conditions, chemical, mechanical, thermal and electric impact such as vibration, humidity and corrosion (see IEC/EN 60079-14).
- The device must only be installed by trained qualified personnel who is familiar with the relevant standards.

# NOTICE

Malfunction or device damage caused by condensation.


Non-compliance can result in material damage!

- operate the luminaire continuously or periodically over extended periods of time.
- avoid thermal bridges.



# 8.1 Dimensions / fastening dimensions

# Dimensional drawings (all dimensions in mm [inches]) – Subject to modification




Dimen-	Luminaire	
sions	Size 2	Size 4
L1	857 [33.74]	1467 [57.76]
L2 <sup>1)</sup>	400 [15.75]	800 [31.50]
L3 <sup>2)</sup>	320 to 480 [12.60 to 18.90]	670 to 930 [26.38 to 36.61]

<sup>1)</sup> fixed mounting distance

## **EXLUX 6009/4**

# Dimensional drawings for assembly parts and accessories (all dimensions in mm [inches]) – Subject to alterations




Mounting rail

15779E00

<sup>2)</sup> variable mounting distance

# Dimensional drawings for assembly parts and accessories (all dimensions in mm [inches]) - Subject to alterations





Ring bolt fitted in insert nut of the luminaire

Mounting bracket fitted in mounting rail


Pipe clamp fitted in mounting rail

15783E00





# Wall mounting bracket fitted in mounting rail



Dimensions	Luminaire	
	Size 2	Size 4
L1	1135 [44.69]	1744 [68.66]
L2	390 [15.35]	338 [13.31]

Linear luminaire EXLUX with pole mounting sleeve



# 8.2 Removing protective foil

As standard, the luminaire is generally delivered with protective foil on the translucent cover. However, in some cases, it can be delivered without protective foil.



## **DANGER**

Explosion hazard due to electrostatic discharge! Non-compliance results in severe or fatal injuries.

- · Only remove protective foil in safe areas.
- If protective foil is available:
   Remove protective foil prior to commissioning.

# 8.3 Mounting / dismounting, operating position



# **DANGER**

Explosion hazard due to electrostatic discharge! Non-compliance results in severe or fatal injuries.

Do not use the luminaire in strong charge generating environments!

The following processes/activities should be avoided:

- accidental friction
- particle currents



# **DANGER**

Explosion hazard due to inadmissible heating!

Non-compliance results in severe or fatal injuries.

- Avoid external heat sources and/or direct sunlight (risk of change of temperature class or change of maximum permissible surface temperature).
- Do not exceed the maximum ambient temperature due to external heat sources (premature failure of equipment).




The luminaire is suitable for wall and ceiling mounting.

In event of wall mounting in outdoor areas, avoid installation with central lock at top.

The mounting position with upward light emission in outdoor areas is prohibited.

# Suspension at fixed mounting points




Size	L2 mm [inch]
2	400 [15.75]
4	800 [31.50]

max. screw-in depth 10 mm [0.39]



# Suspension at movable mounting parts




Mounting bracket		l op rail
Size	L4 mm [inch]	L mm [inch]
2	320 [12.60]	80 [3.15]
4	670 [26.38]	130 [5.12]

Lateral mounting pockets for variable points of suspension.



When mounting the luminaire using top rails, ensure that the mounting surface is flat. Otherwise, the enclosure might be mounted in a warped/ twisted way. The result is leakage of the luminaire and difficulties in replacing the translucent cover.


# Pole mounting using pole mounting sleeve





# Pole suspension Pole mounting using pipe clamps






Size	L4 mm [inch]	L mm [inch]
2	320 [12.60]	80 [3.15]
4	670 [26.38]	130 [5.12]



For pipe clamp mounting, use the solution of R. STAHL Schaltgeräte GmbH with integrated mounting rail providing reliable and stable four-point fixing! In case of point suspension using pipe clamps,

R. STAHL Schaltgeräte GmbH does not guarantee the strength and tightness of the luminaire!

# Wall bracket mounting



Size	L4 mm [inch]	L mm [inch]
2	320 [12.60]	80 [3.15]
4	670 [26.38]	130 [5.12]

# 8.4 Installation

# 8.4.1 Opening and Closing of the Enclosure



# **DANGER**

Risk of electric shock due to improper opening!

Non-compliance results in severe or fatal injuries.


 Open luminaires without switch only in de-energized state (see information plate on the lock)!



## Recommendation

Opening and closing of the luminaire by using a socket wrench from R. STAHL Schaltgeräte GmbH.





- Remove the closing cap of the central lock.
- Turn the central lock using a box spanner M8, spanner size 13, by 90° to the left as far as it will go.
- Swivel down the translucent cover.
- Proceed in reverse order to close.
- The seal of the translucent cover must lie correctly on the sealing edge.
- Push the closing cap onto the central lock opening (protection against dirt).




Observe the following during mounting and dismounting:

- Version without switch: Disconnect the luminaire from the power supply, secure it against being switched on again and open the battery case in order to disconnect from the battery voltage.
- Do not use force when opening or closing the enclosure.

#### Central lock

- Version with switch: The luminaire is positively disconnected from the power supply by actuating the central lock.
- In open end position and with translucent cover swivelled down, an anti-pumping device prevents the central lock from being actuated.

# Opening and closing the reflector plate




## Opening:

- Open the reflector plate by pressing down on the safety latch (1).
- Swivel down the reflector plate (2).

## Closing:

• Flip up the reflector plate and snap it into place.

# Opening and closing the battery case



## Opening:

- Loosen the screws (1) (cross head H2).
- Open the battery cover (2). Closing:
  - Close the battery cover (2).
  - Tighten the screws (1) (cross head H2) firmly (2 Nm).

# 8.4.2 Electrical connections Electrical connection

Observe the maximum clamping possibility of the connection terminals (see chapter "Technical data").

Observe the following when connecting to the electrical connection:

- · Clamping must be carried out precisely.
- Do not clamp any part of the conductor insulation.
- · Do not mix up the conductors.
- · Observe the technical regulations when connecting the conductor.
- Clamp the conductor firmly.
- The phase L1 must be directly connected to the grid which functions as charging phase for the battery!

# NOTICE

Danger due to wrong connection.

Malfunction

Phases L and L1 must be connected in phase.



#### Connection terminals

# Clamping range:

1 x 1.5 to 6 mm<sup>2</sup> (solid)
1 x 1.5 to 4 mm<sup>2</sup> (finely stranded)
1 x 1.5 to 6 mm<sup>2</sup> (finely stranded with core end sleeves)

(2 free clamping units per pole available)

# Stripping length:

10 to 12 mm

## Standard:

L'	
L3	
L2	
L1	
N	
PE	

L' = switched phase L1 = charging phase

L2, L3 = phase

Ν = neutral conductor PE = protective conductor

20294E00

# with DALI connection:

D2	
D1	
L'	
L3	
L2	
L1	
N	
PE	

= DALI connection D1, D2

L' = switched phase L1 = charging phase

L2, L3 = phase

Ν = neutral conductor PΕ = protective conductor


# Through wiring of the mains supply connection



Through wiring with 2.5 mm<sup>2</sup> cross section for max. 16 A.

# Connection of remote switch to control gear

Connecting the remote switch to the potential-free contact "Remote switch" of the control gear.



# Clamping range:

1.5 mm<sup>2</sup> solid, finely and extra finely stranded

Stripping length:
8.5 to 9.5 mm

18475E00

#### 8.4.3 Cable entries

The standard luminaire is delivered with 3 lead-in holes, 2 cable glands and 2 stopping plug.

Tightening torques for components from R. STAHL Schaltgeräte GmbH

Luminaires with installed cable entries and stopping plugs from

R. STAHL Schaltgeräte GmbH must be tightened using the following values:

		Tightening torque	
		Connection thread	Pressure screw
Cable entry 8161	M20 x 1.5	2.3 Nm	1.5 Nm
	M25 x 1.5	3.0 Nm	2.0 Nm
Stopping plugs	M20 x 1.5	1.0 Nm	-
8290	M25 x 1.5	1.5 Nm	_

Luminaires with cable entries and stopping plugs which are not supplied by R. STAHL Schaltgeräte GmbH



# **DANGER**

Explosion hazard due to impermissible cable entries and stopping plugs! Non-compliance results in severe or fatal injuries.

 Only use separately certified cable glands and stopping plugs which have been tested and certified according to Directive 2014/34/EU (ATEX) or IECEx (CoC) and which comply with the standard version stated in the certificate of the luminaire.



### Please observe the following:

- · the required dust resistance!
- the required type of protection!
- the required temperature resistance!
- the IP degree of protection according to the rating plate!
- the operating instructions of the cable entries and stopping plugs!
- · the required tightening torques!
- the range of the permissible cable diameter!
- Insert the metal cable entries and/or stopping plugs into the PE!

# 9 Commissioning



# **DANGER**

Explosion hazard due to incorrect installation!

Non-compliance results in severe or fatal injuries.

- · Check the device for proper installation before commissioning.
- · Comply with national regulations.

# **NOTICE**

Malfunction or device damage caused by condensation.

Non-compliance can result in material damage!

- operate the luminaire continuously or periodically over extended periods of time.
- · avoid thermal bridges.

Before commissioning, ensure the following:

- · Check the mounting and installation.
- Inspect enclosure for damage.
- If necessary, remove foreign bodies.
- If necessary, clean the connection chamber.
- · Check if the conductors have been inserted correctly.
- Check if all screws and nuts have been tightened firmly.
- Check if all drilled holes are closed.
- Check whether all the cable entries and stopping plugs have been tightened firmly.
- Check if all conductors have been clamped firmly.
- Check if the line voltage and the rated operational voltage are consistent.
- Check if the permissible conductor diameter for the corresponding cable entries have been used.
- Check if the device is closed according to regulations.
- Check if the battery is connected.
- If necessary remove transport protection (foam cushion).
- · Check if the LED assembly and the diffuser are clean.
- · Check that there is no protective foil on the translucent cover.

# 10 Operation

# 10.1 Operating Modes

# Power supply operation:

Stand-by operation The luminaire is switched off regardless of normal lighting.


Continuous operation The luminaire is switched on regardless of normal lighting.

Normal lighting operation The light fitting is operated by normal lighting.

# **Emergency light operation:**

In the event of a power failure, the luminaire switches to emergency light operation. The luminaire is switched on regardless of the operation mode of the selected rated operating time.

## Rated operating time



Rated operating time 


Jumper between terminals 8 and 9 of the control gear

1.5 hours open3.0 hours closed



# Emergency light blocking

A remote switch for emergency light blocking can be connected to terminals 10 and 12 of the control gear.



Remote switch is closed

Power supply operation

Power failure

Switching on the luminaire depending on operation mode Emergency light function

Remote switch is opened

Switching on the luminaire depending on operation mode No emergency light function

# 10.2 Functional and rated operating time test

To carry out the test, the following prerequisites must be fulfilled:

- · the time interval has expired.
- the power supply operation was active for at least 1 hour.
- the remote switch is closed.

The test result is shown on the LED indicator. During a test the luminaire is switched on.

## **Function test**

- · starts within 24 hours after commissioning.
- is carried out every 7 days.
- takes 1 minute.
- checks the function of the LEDs and the battery.

## Rated operating time test

- · starts within 44 days after commissioning.
- is carried out once a year.
- checks the function and the operating time of the luminaire during emergency light mode.
- is repeated after 14 days if rated operating time test is faulty.



# 10.3 Indications

# When connecting to the power supply

Initialisation within 10 seconds

Second	Description	
0 to 2	Function test green LED	
2 to 4	Function test red LED	
4 to 10	Status rated operating time test	Green LED flashes - rated operating time test active
		Green LED off - rated operating time test not active

Then the LED indicator switches to operating mode.

# During power supply operation

Blinking: 1 second on, 1 second off

Flashing: 0.25 seconds on, 0.75 seconds off

Green	Luminaire is ready for operation	
Blinking green	Luminaire is ready for operation	Function and rated operating time test activated
Red	Error	Battery is defective or electric circuit is interrupted
Blinking red	Error	Last function and/or rated operating time test faulty
Flashing red	Error	LEDs defective
Blinking green/red	Luminaire is ready for operation, no emergency light operation	Emergency light operation is deactivated by remote switch
Flashing green/red	Luminaire is ready for operation	Reset signal detected

# During emergeny light operation

The LED indicator is switched off.



# 10.4 Troubleshooting

Refer to the following troubleshooting chart during troubleshooting:

Cause of error Troubleshooting

The LEDs are defective. Replace the mounting plate including

LEDs and the control gear.

The control gear is defective. Replace the mounting plate including

LEDs and the control gear.

The switch is defective. Replace the switch.

**Red LED indicator** 

The battery is defective. Replace the battery. The switch in the battery box is defective. Replace the switch. The switch in the luminaire is defective. Replace the switch.

LED indicator blinking red

The battery capacity is too low. Replace the battery.

The LEDs are defective. Replace the mounting plate including

LEDs and the control gear.

The LED indicator lights up in green after troubleshooting.

If the error cannot be eliminated using the mentioned procedures:

Contact R. STAHL Schaltgeräte GmbH.

For fast processing, have the following information ready:

- Type and serial number of the device
- · Purchase information
- Error description
- Intended use (in particular input / output wiring)

# 11 Maintenance, Overhaul, Repair



## CAUTION

Risk of electric shock or malfunction of the device due to unauthorized work! Non-compliance can result in light injuries!

- Before carrying out work on the device, switch off voltage supply.
- Work performed on the device must only be carried out by authorized and appropriately trained qualified electricians.

#### 11.1 Maintenance

- Consult the relevant national regulations to determine the type and extent of inspections.
- Adapt inspection intervals to the operating conditions.
- Perform maintenance and repair work in accordance with IEC 60079-17 and IEC 60079-19.




Observe the relevant national regulations in the country of use.

As a minimum, check the following points during maintenance work on the device:

- · Whether the clamping screws holding the cables are securely seated
- Whether the device enclosure and/or protective enclosure have cracks or other visible signs of damage
- Whether the seal shows signs of ageing or damage (completely replace enclosure components with damaged foamed seal)
- · Whether the device is clean inside and out
- Whether the permissible temperatures (in accordance with EN 60079) are complied with
- Whether the cable entry is intact and securely tightened
- Whether the cables and lines show signs of ageing and damage
- Intended use and function.



# 11.1.1 Replacing the luminaire cover



06058E0

- · Open the luminaire.
- Swivel the translucent cover backwards by 180°.
- Lift the translucent cover to detach it from the hinge.
- Insert new translucent cover into the hinge.
- All hinges must engage correctly.
- Close the luminaire.
- Observe safety notes!

# 11.1.2 Battery replacement



# **DANGER**

Explosion hazard due to explosive dust atmosphere! Non-compliance results in severe or fatal injuries.


• Do not replace or transport the battery in explosive dust atmosphere!



# **WARNING**

Danger due to sparking! Explosion protection is impaired!


- Carry the battery cover with built-in battery secured on the wrist.
- · Put the strap of the battery case around the wrist.



Screws 1 4 Battery plug 2 Battery cover 5 **Battery** 3 6 Switch Strap


- Loosen the screws (1) (cross head H2) in the battery cover (2).
- Open the battery case.
- The switch (6) disconnects the battery circuit.
- Secure the battery cover with installed battery to your wrist using the strap (3).





16406F00

- Remove the battery plug from the chamber.
- Disconnect the battery plug (4).
- Take off the battery cover with installed battery (5).
- Put on and secure the battery cover with installed battery (5).
- Connect the battery plug (4).
- Loosen the strap (3) from the wrist and store it in the battery case.



21447E00

- Close the battery case. Fix battery conductors in place to protect them against getting caught between the plastic domes (6).
- Tighten the screws (1) (cross head H2) firmly (2 Nm).

# Resetting the error indication "blinking red" after replacing the battery



The error indication "blinking red" remains active after successfully replacing the battery.

#### Deactivation:

#### Automatic:

- After replacing the battery a rated operating time test is carried out automatically within 14 days.
- The error will be reset once this test has been passed successfully.

#### Manual:

- The line voltage must be switched on.
- Actuate the switch in the battery case for 5 seconds.
- · Release the switch.
- Actuate the switch twice within 10 seconds for a duration of 2 seconds.
- Resetting of the error will be shown on the LED indicator for 5 seconds by blinking red/green.
- · The error is reset.
- Close the battery case.

# 11.2 Repair



# **DANGER**

Explosion hazard due to improper repair!

Non-compliance results in severe or fatal injuries.

 Repair work on the devices must be performed only by R. STAHL Schaltgeräte GmbH.

# 11.3 Returning the device

- Only return or package the devices after consulting R. STAHL!
   Contact the responsible representative from R. STAHL.
- R. STAHL's customer service is available to handle returns if repair or service is required.
- Contact customer service personally.

or

- · Go to the r-stahl.com website.
- Under "Support" > "RMA" > select "RMA-REQUEST".
- · Fill out the form and send it.
  - You will automatically receive an RMA form via email. Please print this file off.
- Send the device along with the RMA form in the packaging to R. STAHL Schaltgeräte GmbH (refer to chapter 1.1 for the address).



# 12 Cleaning

- To avoid electrostatic charging, the devices located in potentially explosive areas may only be cleaned using a damp cloth.
- When cleaning with a damp cloth, use water or mild, non-abrasive, non-scratching cleaning agents.
- Do not use aggressive detergents or solvents.
- Never clean the device with a strong water jet, e.g. using a high-pressure washer!

# 13 Disposal

- Observe national and local regulations and statutory regulation regarding disposal.
- Separate materials when sending it for recycling.
- Ensure environmentally friendly disposal of all components according to the statutory regulations.



## **CAUTION**

Danger due to chemical reactions! Human health and the environment are at risk! Batteries

- · collect them separately
- · dispose of them in controlled fashion
- do not dispose of them in the domestic waste
- return them to public collection points or to the supplier

# 14 Accessories and Spare parts

# **NOTICE**

Malfunction or damage to the device due to the use of non-original components. Non-compliance can result in material damage.

Use only original accessories and spare parts from R. STAHL Schaltgeräte GmbH.

	Figure	Description	Art. no.	<b>Weight</b> kg
Battery set		Battery cover with built-in battery. Gas-tight NiCd battery; 7 Ah / 6 V	223532	1.195



For accessories and spare parts, see data sheet on our homepage r-stahl.com.



# EU-Konformitätserklärung

EU Declaration of Conformity Déclaration de Conformité UE



# R. STAHL Schaltgeräte GmbH • Am Bahnhof 30 • 74638 Waldenburg, Germany

erklärt in alleiniger Verantwortung, declares in its sole responsibility, déclare sous sa seule responsabilité,

dass das Produkt:

that the product: que le produit:

**LED Notlichtleuchte** 

LED Emergency luminaire

LED Luminaire de secour

Typ(en), type(s), type(s):

6009/4.

mit den Anforderungen der folgenden Richtlinien und Normen übereinstimmt.

is in conformity with the requirements of the following directives and standards. est conforme aux exigences des directives et des normes suivantes.

Richtlinie(n) /	Directive(s) / Directive(s)	Norm(en) / Standard(s) / Norme(s)		
<b>2014/34/EU</b> 2014/34/EU 2014/34/UE	ATEX-Richtlinie ATEX Directive Directive ATEX	EN IEC 60079-0:2018 EN 60079-1:2014 EN IEC 60079-7:2015/ A1:2018 EN 60079-11:2012 EN 60079-18:2015 EN 60079-28:2015 EN 60079-31:2014		
Kennzeichnun	g, marking, marquage:	(Ex) II 2 G Ex db eb ib mb op is IIC T4 Gb II 2 D Ex tb op is IIIC T 100 °C Db	<b>C</b> € <sub>0158</sub>	
EU-Baumusterprüfbescheinigung: EU Type Examination Certificate: Attestation d'examen UE de type:		IBExU 16 ATEX 1199 (IBExU Institut für Sicherheitstechnik GmbH Fuchsmühlenweg 7, 09599 Freiberg, Germany)		
Produktnormen nach Niederspannungsrichtlinie: Product standards according to Low Voltage Directive: Normes des produit pour la Directive Basse Tension:		EN 60598-1:2015/ A1:2018 EN 60598-2-22:2014/ AC:2016 EN 62471:2008		
<b>2014/30/EU</b> 2014/30/EU 2014/30/UE	EMV-Richtlinie EMC Directive Directive CEM	EN 61547:2009 EN 55015:2013 + A1:2015 EN 61000-3-2:2014 EN 61000-3-3:2013		
<b>2011/65/EU</b> 2011/65/EU 2011/65/UE	RoHS-Richtlinie RoHS Directive Directive RoHS	EN 50581:2012		

Waldenburg, 2020-07-14

Ort und Datum Place and date Lieu et date i.V.

Dr. A. Kaufmann

Senior Vice President Marketing & Innovation Vice-Président directeur Marketing & Innovation

I.V.

J. Freimüller

Vice President global Quality Management Vice-Président globale Gestion de Qualité